

GREEN LIFTS



Changing The Way Water Moves



Energy Saving Green Lift Station

The First Real Breakthrough In Wastewater Lift Station Operating Design Since The 1940's

Inventor: Fred Mehr, PhD

Patent Awarded January 23, 2013 – Control Panel



Patent Awarded July 15, 2014 – Green Lift-Station Design Patent Awarded June 17, 2014 – Green Recycled Wet Well



N	Unite ^{Mehr}	d States Patent	t No.: of Patent:	US 8,777,584 B2 Jul. 15, 2014	
54)	ENERGY	SAVING GREEN WASTEWATER	(56)	Reference	es Cited
	PUMPSI	ATION DESIGN	U	.S. PATENT D	DOCUMENTS
(76)	Inventor:	Nasser Fred Mehr, Fort Lauderdale, FL (US)	3,630,637 A 4,341,983 A 5,190,442 A 5,591,010 A 6,186,743 B	* 12/1971 F * 7/1982 G * 3/1993 J * 1/1997 V 1* 2/2001 F	Repp 417/7 Gottliebson 318/102 Iorritsma 417/12 Van Zyl 417/12 Romer 417/12
-)	Nouce.	patent is extended or adjusted under 35	* cited by exami	ner	
		U.S.C. 154(b) by 257 days.	Primary Examin	er - Charles	Freay
(21)	Appl. No.:	13/335,908	(57)	ABSTI	RACT
22) (65) (51) (52)	Filed: US 2013/0 Int. Cl. F04B 49/0 F04B 41/0 U.S. Cl. USPC	Dec. 22, 2011 Prior Publication Data 0164149 A 1 Jun. 27, 2013 04 (2006.01) 06 (2006.01) 	An energy savi design that elim waste water pum pumps and incre a primary pump during high den primarily as a b station designs, Design utilizes a dent float switcl station designs, trollable panel fi pumps on a sche determining in-h operating points	ng three pum inates the hig p stations, red ases the useful unning contin and periods a ack up pump the Energy is single float sw ues trigger stat he Green desi or rotating the dule. This desi flow rates for a of pumps so	p waste water pump station h energy usage of traditional luces maintenance costs to the lives of the pumps by having uously, a second pump mining and a third pump functioning , Unlike conventional pump Saving Green Pump Statior witch panel. Whereas indepen- ristops in conventional pump gin incorporates a remote con- primary, secondary and third ign also provides a process for a pump station and efficiency that the most efficient pumps
(58)	Field of C	Tassification Search 417/36, 40, 41, 53, 5, 7, 8, 12	with the lowest	horsepower ca	in be selected.
	See applic	ation file for complete search history.	1	Claim 18 Da	rowing Sheets











(12) United States Patent Mehr

(10) Patent No.: US 8,371,821 B1 Feb. 12, 2013 (45) Date of Patent:

- (54) GREEN WASTE WATER PUMP STATION **CONTROL SYSTEM**
- (76) Inventor: Nasser Fred Mehr, Fort Lauderdale, FL (US)
- (*) Notice: Subject to any disclaimer, the term of this patent is extended or adjusted under 35 U.S.C. 154(b) by 0 days.
- (21) Appl. No.: 13/588,840
- (22) Filed: Aug. 17, 2012
- (51) Int. Cl. F04B 41/06 (2006.01)
- F04B 49/04 (2006.01) (52) U.S. Cl. .. 417/8; 417/7; 417/12; 417/40
- (58) Field of Classification Search . 417/5, 7, 417/8, 12, 40

See application file for complete search history.

(56) **References** Cited

U.S. PATENT DOCUMENTS

3,741,683	Α	*	6/1973	McTamaney	et al	417/
4,341,983	A	٠	7/1982	Gottliebson		18/102
4,437,811	Α	*	3/1984	Iwata et al.		417/

5,909,352	А		6/1999	Klabunde et al
6,186,743	BI	٠	2/2001	Romer
2008/0011377	AI		1/2008	Van Hooren et al 138/118
2009/0202359	AI	٠	8/2009	Duncan 417/43

*-cited by examiner

(57)

Primary Examiner - Charles Freay

ABSTRACT

An electrical control system for energy efficient pump stations providing for continuous operation of a single primary pump with a second pump functioning as the support pump and a third pump acting as the standby/emergency pump. All pumps are of equal horsepower and horsepower selection is determined by the system curve to select the lowest, most efficient horsepower necessary to discharge water at the highest inflow rate while not allowing the water level to drop below the submerged pump level during continuous running of the primary pump. A timer having an indicator arm rotates one full revolution every thirty days changing the pump sequence to reduce wear and tear on individual pumps. Each pump functions as the primary, secondary and backup/emergency pump for the same number of hours during the monthly cycle. Adding control circuits enables one or more pumps to be added when necessary.

2 Claims, 3 Drawing Sheets







Traditional 2 pump lift - Stations





Submerged 3 Pumps With VFD



-24" INFLUENT GRAVITY SEWER WALL PIPE. -12' ID DIA PRECAST CONCRETE WET WELL CONFORMING TO ASTM C-478 & SPECIFICATIONS 3'-6"* 3'-6"* PUMP NO.3 PUMP NO.2 PUMP NO.1 GUIDE BARS-8" DIP DISCHARGE-PIPING, (TYP)

Submerged 3 Pumps With VFD





Dry Well With 3 Pumps





Dry Well With 3 Pumps





3 Pump Green Lift Stations

4 Pump Green Lift Stations





24 Hour Inflow Into Lift - Station





Traditional lift station with 2 pumps, 160 GPM/each, pump #1A cycles on and off as determined by flow and pump #2B is the backup

Periodic Fill-Up and Pumping





Operating time of 160 GPM pump in the traditional 2 pump lift station; pump #1A cycles 17 times/24 hrs, pump #2B cycles 1 time/24 hrs

Periodic Discharge to Force Main





Power demand on a utility company – traditional 2 pump lift station

Periodic Power From Utility Network



Green lift station with 3 pumps, 80 GPM/each, pump #1A runs continuously, pump #2B runs periodically & pump #3C rarely runs/operating as stand-by



G.L. Station Continuous Fill-Up and Pumping



Operating times of 80 GPM pumps in the green design 3 pump lift station; pump #1A cycles 1 time per month, pump #2B cycles 6/24 hrs and pump #3C cycles 1 time/24 hrs



HOURS

G.L. Station Continuous Discharge to Force Main





Power demand on a utility company - green design 3 pump lift station

Traditional max = 107.6 amps vs **Green** max of 66.34 amps resulting in **38% reduction on power** demand from the utility company by green designed station.

G.L. Station Continuous Power From Utility Network



Traditional lift station with 2 pumps, 160 GPM/each, pump #1A cycles on and off as determined by flow and pump #2B is the backup



Green Lift Stations vs. Traditional Stations

"Fill-Up and pumping"

Green lift station with 3 pumps, 80 GPM/each, pump #1A runs continuously, pump #2B runs periodically & pump #3C rarely runs/operating as stand-by





Operating time of 160 GPM pump in the traditional 2 pump lift station; pump #1A cycles 17 times/24 hrs, pump #2B cycles 1 time/24 hrs

Q = GPM Q = GPM PUMP #2 AFTER WATER LEVEL IS AT MAX. ELEV. WATER LEVEL AT FILL-UP ELEV. +9 WATER LEVEL 80 IN-FLOW = OUTFLOWWATER LEVEL ELEV. <+9 FLEV. +9 40 120 100 80 60

HOURS Operating times of 80 GPM pumps in the green design 3 pump lift station; pump #1A cycles 1 time per month, pump #2B cycles 6/24 hrs and pump #3C cycles 1 time/24 hrs



Green Lift Stations vs. Traditional Stations

"Discharge to Force Main"



Power demand on a utility company - traditional 2 pump lift station

Green Lift Stations vs. Traditional Stations

"Power From Utility Network"



Power demand on a utility company - green design 3 pump lift station



Traditional max = 107.6 amps vs **Green** max of 66.34 amps resulting in **38% reduction on power** demand from the utility company by green designed station.



TRADITIONAL LIFT-STATION , A-12

MAX INFLOW : 1312 GMP TOTAL HEAD : 90 Ft PUMPS : 3x 60 HP POWER INPUT : 50 HP /Each PUMP MAX DESIGN FLOW :0.75x MAX = 980 GP PUMP MADE: FLYGT, NT 3202 HT-3-480

Refer to Figure and the following TABLE

IN PERIODS A, B, and C, ONLY PUMP # 1 WILL OPERATES, AND ONLY WITH STORAGE "S1-T" IN PERIODS OF D & E, BOTH PUMPS (P#1& P#2) OPERATE WITH STORAGE CAPACITY OF "S1-T + S2-T".

 $S_{1-T} = 7.5 x L x H x (W_1 + W_2)/2$

 $S_1 - T = 7.5 \times 20 \times 1.5 \times (9.5 + 7)/2 = 1856$ Gallons

 $S_2-T = 7.5 \times 20 \times 10 \times 0.5 = 750$ Gallons



TRADITIONAL LIFT-STATION



TRADITIONAL OPERARING ENERGY CONSUMPTION,

FOR PERIODS OF A, B, and C THE PUMP "RUN" TIME and "OFF "TIME WILL BE CALCULATED BY THE FOLLOWING EQUETIONS

WHERE:

"S1", IS SAME AS "S1-T" "S2", IS SAME AS "S2-T"

P #1,("OFF") TIME = S1 / INFLOW GPM

P #1, ("RUN") TIME = S1 / (P#1GPM - INFLOW GPM)

FOR PERIOD OF D & E, THE " OFF " TIME and THE " ON " TIME FOR BOTH PUMPS ARE GIVEN BY;

P #2 ("OFF") TIME = S2(" FILL UP") = S2/ (INFLOW GPM - P#1GPM)

(P#1 + P#2) ("RUN") TIME = (S1 + S2) / (P#1 GPM + P#2 GPM - INFLOW GPM)

SUMMARY OF CACULATION IS GIVEN IN THE FOLLOWING TABLE



TRADITIONAL THREE PUMP LIFT-STATION, DRY WELL (3x 60 HP)

					Pump #	1 As Le	ad Pump)		Pump #	2 As La	ck Pump	
Identify	Inflow	Inflow	Period	Off	Run	Cycle	Number	Total	Off	Run	Cycle	Number	Total
Period	As	As	Duration	Time	Time	Time	of	Run	Time	Time	Time	of	Run
	%	GPM	(Hours)	(Mins)	(Mins)	(Mins)	Cycles	(Hours)	(Mins)	(Mins)	(Mins)	Cycles	(Hours)
Α	50%	656	9	2.83	5.658	8.49	64	6.04	540	0	0	0	0
В	68%	892	4	2.08	20.17	22.25	10.8	3.36	240	0	0	0	0
С	75%	980	4	1.894	238.1	240	1	4	240	0	0	0	0
D	85%	1,115	5	1.665	8.78	10.445	28.72	4.2	7.39	3.055	10.445	28.72	1.462
E	100%	1,312	2	1.414	6.264	7.676	15.63	1.632	3.704	3.972	7.676	15.63	1.035
TOTAL			24				120.15	19.5	•		44.352	2.497	

3x 60 HP PUMPS, FLYGT, MODEL# NF3202 HT-3-480V, Rushing Current 470 Amps, Rated Current 69 Amps

Efficiency a v e. (pump) = (E. A x A time +E. B x B time +E. C x C time +E.D x D time +E.E x E time)/ 24

Effi. a v e . (FLYGT 60HP PUMP) = $(9 \times 58 \% + 4 \times 44 \% + 4 \times 45 \% + 5 \times 50 \% + 2 \times 58 \%)/24 = 51.8\%$

KWH (L.S.) = KWH (P#1 + P#2) = KWH r + KWH m + KWH f + KWH k



TRADITIONAL LIFT-STATION POWER CONSUMPTION/ 24 HOURS

KWH r = Running KWH = 50HP x 0.746(19.5 Hrs.+ 2.5 Hrs.) = 820.6 KWH

KWH m = Start up KWH = $1.73x 480V \times 470$ Amps X 5 sec/ 3,600,000 = 0.542 kwh

KWH f = Flow Establishment KWH = 1.73X 480Vx 69 Amps x 0.8X 1 min/ 60,000 = 0.764 KWH

KWH k = Kinetic Energy of Moving WATER in FORCE MAIN = $\frac{1}{2}(M \times V \times V)$

a - For (P#1) Running = 0.072 KWH

b - For (P#1 + P#2) Running = 0.285 KWH

KWH /Start P #1 = 0.542+0.764+0.072 = 1.379 KWH

KWH / Start (P#1 + P#2) = 2(0.542+0.764+0.285) = 2.898 KWH

KWH for(ON & OFF) of LIFT–STATION in 24 HR s = (P#1) (cycles x Kwh)+(P#1+P#2) (cycles x Kwh) KWH (ON &OFF) =(75.8 x1.379 KWH) + (44.35x2.898 KWH) =233.05 KWH

TOTAL Kwh of LIFT-STATION/ 24 HRs = 233.05 KWH + 820.6KWH = 1,053.65 KWH



GREEN LIFT-STATION DESIGN, A-12

MAX INFLOW : 1312 GPM

MIN INFLOW: 656 GPM

TOTAL HEAD : 90 Feet

PUMPS: MADE BY EBARA, MODEL #150x100 DDLF 622 SYNCHRONOUS, 1,800 RPM / 480V/3 PHASE PUMPS : 3x 30 HP PUMP'S BHP : 26 HP POWER IN PUT : 27.4 HP PUMP'S MAX DESIGNED FLLOW : 656 GPM PUMP'S IMPELLER TRIMED DOWN from 304mm to 295mm FINAL POWER IN PUT : 25 HP STORAGE :

S = 7.5x Lx w x H GALLONS

 $S_{1-G} = 7.5 \times 20' \times 10' \times 1' = 1500 \text{ GALLONS}$ $S_{2-G} = 7.5 \times 20' \times 10' \times 1.5' = 2250 \text{ GALLONS}$



GREEN LIFT-STATION



GREEN LIFT-STATION DESIGNED ENERGY CONSUMPTION,

REFER TO THE FOLLOWING SUMMARY TABLE,

▶ IN A Period, ONLY "PUMP#1" RUNS CONTINUOUSLY with HIGH EFFICIENCY,

MIN. L.S.INFLOW GPM IS EQUAL TO "P#1 GPM", and STORAGE "S1-G" REMAINS FULL IN

ALL THE PERIODS OF A, B, C, D, and E.

- > IN **B**, **C**, **D**, and **E** period, ONLY STORAGE " S_2-G " WILL BE PUMPED OUT PERIODICALLY BY "P #2", WITH HIGH EFFICIENCY.
- > PUMP#2 (" OFF ") TIME= $S_{2g}/(INFLOW GPM P #1GPM)$
- > PUMP#2 (" RUN ") TIME = $S_{2g}/(P#1 \text{ GPM} + P#2 \text{ GPM} \text{INFLOW GPM})$
- P#2 (" CYCEL ") TIME = P#2(" OFF ") TIME + P#2(" RUN ")
- > CYCELS / PERIOD = PERIOD TIME / CYCEL TIME



GREEN LIFT-STATION WITH THREE PUMPS, (3x 30 HP PUMPS)

				Pump # 1 , CONTINUOUS RUN		mp # 2,	RUNS a	s NEEDE	ED
Identify	Inflow	Inflow	Period	RUN	Off	Run	Cycle	Number	Total
Period	As	As	Duration	Duration	Time	Time	Time	of	Run
	%	GPM	(Hours)	(Hours)	(Mins)	(Mins)	(Mins)	Cycles	(Hours)
Α	50%	656	9	9	0	0	0	0	0
В	68%	892	4	4	9.53	5.357	14.89	16.1	1.437
С	75%	980	4	4	6.94	6.78	13.72	17.5	1.977
D	85%	1,115	5	5	4.9	11.42	16.32	18.38	3.5
E	100%	1,312	2	2	0	120	120	1	2
									and a second second
TOTAL			24	24			53	8.914	

3x 30 HP PUMPS, MADE by EBARA, MODEL # 150 x 100 DDLF 622, 480V/ 3 PHASE, 1800 RPM, SYNCHRONE

IMPELLER TRIMMED OFF from 304 mm TO 295 mm, THAT REDUCED THE INPUT POWER by FACTOR of 0.914 PUMP'S INPUT HP = 27.4 HP x 0.914 = 25 HP

DESIGNED PUMP'S MAX INFLOW = L.S.'S MIN INFLOW = 656 GPM

PUMP'S EFFICIENCY for PERIOD A, B, C, D, and E IS THE SAME AND IS AT THE DESINGED EFFICIENCY OF 63 %

KWH(L.S.) = KWH(P#1+P#2) = KWH r + KWH m + KWH f + KWH k



GREEN LIFT-STATION POWER CONSUMPTION / 24 HOURS

KWH r = Running KWH = 25HP x 0.746(24 Hrs. + 8.9 Hrs.) = 613.83 KWH

KWH m = Start up KWH = 1.73x 480V x 191Amps X 5 sec/ 3,600,000 = 0.220 KWH

KWH f = Flow Establishment KWH = 25 HP x 0.746 x 1min/ 60,000 = 0.311 KWH

KWH k = Kinetic Energy of Moving WATER in FORCE MAIN = $\frac{1}{2}$ (M x V x V)

a - For (P#1) Running = 0.032 KWH

b - For (P#1 + P#2) Running = 0. 127 KWH

KWH (ON & OFF) P#1 =0.0 P#1 Runs Continuously

KWH (ON & OFF) P # 2 = 0.220 KWH + 0.311 KWH + 0.032 KWH = 0.563 KWH

KWH for (ON & OFF) of LIFT-STATION in 24 HR s = (P#2) (cycles x KWH)

KWH (ON &OFF) for L.S. = 52 cycles x 0.563 KWH = 29.86 KWH

TOTAL Kwh of GREEN-LIFT-STATION/ 24 HRs = 613.83 KWH + 29.86 KWH = 643.71 KWH



GREEN LIFT-STATION with THREE CONSTANT SPEED PUMPS, A-12

VERSUS

TRADITIONAL L. STATION with THREE CONSTANT SPEED PUMPS

GREEN -LIFT "HP "CAPACITY installed / TRADITIONAL "HP "installed = 3x 30/3x 60 = 50 % GREEN-LIFT ENERGY SHAFT BHP/TRADITIONAL ENERGY SHAFT BHP = 643.7/1,053.7 = 61.1 % GREEN-LIFT ERERGY INPUT / TRADITIONAL ENERGY INPUT = (51.83 % / 63 %) x 61.1 % = 57.6 % MAINTENANCE IS RELATED TO NUMBER OF PUMP'S " ON & OFF " or the NUMBER OF CYCLES TRAD. PUMP " LIFE "/GREEN PUMP " LIFE " = TRAD.CYCLES/ GREEN CYCLES = 53/ 164.5 = 32.7 % MAINT. G.L.STATION / MAINT. TRADITIONAL = 53/(120.15+44.35) = 53/164.5 = 32.7 % GREEN-LIFT " CO2 " RELEASE / TRADITIONAL " CO2 " RELEASE = 643.7/1,053.7 = 61.1 % ONLY GREEN LIFT-STATION CAN RECEIVES FEDERAL GRANT



CASE STUDY

We have performed a case study of an existing, traditional design, re-pump station. The study compared criteria and specifications (Table 1 below) of the traditional station with those of an energy efficient green designed station. Comparative costs of the construction of the traditional and green designed stations are presented in Table 2. Finally, the maintenance and energy cost savings of each designed station are provided in Table 3.

TABLE 1							
Item Description	Traditional Design	Green Design					
Wet Well							
Inner Diameter X Wall Thickness Depth	12'x1' 30'	12'x1' 24'					
Pumps							
Average Operating Efficiency	12%	63%					
Maximum Inflow to Well	1750 GPM	1750 GPM					
Pump Rated Power	85 HP	30 HP					
/oltage	480 V	480 V					
Nominal Rated Amps	109 A	36 A					
Rush in Current (LRA)	685 A	231 A					
Rated Speed	1185 RPM	1755 RPM					
mpeller Diameter	15.875"	5.9375"					
Pump Height	56.5"	39.25"					
Pump Wieght (With/Without Jacket)	2066/1900	665/600					

CRITERIA AND SPECIFICATIONS TRADITIONAL RE-PUMP STATION VS. GREEN DESIGN

		1	TABLE 2	2				
	Camallia	TRADITIONAL		GREEM	DESIGN	GREEN DESIGNED STATION SAVINGS		
Item Description	Compiling Cost Items	Materials	Labor	Materials	Labor	Materials	Labor	
Cost Of Construction								
Wet-Well	13/C.I.	\$29,767	\$14,034	\$23,054	\$11,417	22.55%	18.65%	
Pumps & L	2/C.I.	\$144,426	\$15,865	\$73,316	\$6,831	49.24%	56.94%	
Piping & Valves	12/C.I.	\$43,996	\$22,000	\$24,474	\$12,237	44.37%	44.38%	
Electrical	16/C.I.	\$158,028	\$62,070	\$96,720	\$38,795	38.80%	37.50%	
Emergency Generator	3/C.I.	\$70,820	\$18,665	\$52,480	\$13,500	25.90%	27.67%	
Coffer Dam	9/C.I.	\$40,022	\$16,000	\$34,653	\$16,000	13.42%	0.00%	
Excavation	11/C.I.	\$8,307	\$8,667	\$6,069	\$6,429	26.94%	25.82%	
Dewatering	6/C.I.	\$6,400	\$7,680	\$4,800	\$5,760	25.00%	25.00%	
Wet-Well Installation	20/C.I.	\$24,454	\$23,077	\$17,512	\$17,727	28.39%	23.18%	
Totals		\$526,220	\$188,058	\$333,078	\$128,696	36.70%	31.57&	
Total Cost Materials & Labor		\$714,278		\$461,774		35.35%		

CONSTRUCTION COST COMPARISON

TABLE 3								
COST OF OPERA- TION (25 YRS)	TRADITIONAL	GREEN DESIGN	GREEN DESIGNED STATION SAVINGS					
Maintenance	\$1,435,516	\$300,482	79.07%					
Operating Energy Cost	\$6,072,525	\$1,602,660	73.61%					



GREEN LIFT-STATION with (4x 30) HP CONSTANT SPEED PUMPS,

VERSUS

TRADITIONAL L. STATION with (3x85) HP VARIABLE SPEED PUMPS

GREEN -LIFT " HP " CAPACITY installed / TRADITIONAL " HP " installed = 4x 30/3x 85 = 47 % GREEN-LIFT ENERGY CONSUMPTION / TRADITIONAL ENERGY USE = 64,106/242,901 = 26.4 % TRADITIONAL MAINTENANCE IS VERY COSTLY, DUO TO VFD 'S HEAT SENSITIVITY AND VFD'S SHORT LIFE. ALSO LOWERING SPEED COULD CAUSE RESONANCE OF NATURAL FREQUENCY MAINT. G.L.STATION / MAINT. TRADITIONAL = \$12,019 monthly/\$57,421 monthly = 32.7 % GREEN-LIFT " CO2 " RELEASED/TRADITIONAL " CO2 " RELEASED = 64,106/242,901 = 26.4 % GREEN L.-STATION'S PUMP EFFICIENCY IS 63 %, TRADITIONAL L.-STATION AVERAGED 12 %

ONLY GREEN LIFT-STATION CAN RECEIVES FEDERAL GRANT



Why Not Variable Speed Pumps?

- Variable speed pumps have been used in lift stations SUPPOSEDLY to save energy
- On the contrary, they are less efficient than single speed pumps and do not accomplish energy or cost savings
- Dr. Thomas Walski is one of the most published and recognized water-resources modeling experts and educators in the world
- His research concludes In sewage pump station wet well variable speed pumps approach their maximum efficiency only when their variable frequency drive (VFD) is totally bypassed and the pumps run at constant speed.



TWO PUMP

EFFICIENY 0% to 48%



VARIABLE SPEED PUMP 'S CURVE (LIFT-STATION WITH TWO PUMPS)





EFFICIENCY - VARIABLE SPEED, 0% to 50% - SINGLE SPEED, 65% to 70%

5x9³/₄

.65%

700

63% \$60%

55%

15HP

N.P.S.H.

20

10

4

800

5x



100

%

0

<u>CITY'S SEWER SYSTEM ENERGY</u> <u>USE from Sept 2014 to Sept 2015</u>

- ➢ TOTAL ENERGY USED 37,575,515 KWH
- ➢ PUMP STATIONS ENERGY USED 10,382,792 KWH
- ➢ DEEP WELL INJECTION PUMPS 20,313,670 KWH
- ➢ TOTAL PUMPING POWER USED 30,696,462 KWH
- PUMPING ENERGY % OF TOTAL 81.69 %







GREEN LIFT-STATIONS' ALUMINUM or CONCRETE TOP COVERS



Why Not Start



Changing The Way Water Moves Ft Lauderdale, FL 954-540-2863 • www.globalgreenlifts.com



Today?