



GLOBALSM

GREEN LIFTS

Changing The Way Water Moves



June,1,2016

I & I

Inflow of rain water and **I**nfiltration of under
ground water into **sewer system**

BY

Fred N. Mehr, PhD, PE

GLOBAL GREEN LIFT



Effect of “I & I” on sewer system

- Serious
- Unhealthy
- Costly

A- System flow operation

- Inflow
 - Even though is insignificant to total “I & I” it creates surge in sewer handling system of laterals, gravity pipes, manholes, and lift-stations.
 - Sewer system delivers with its max. Capacity flow to treatment plant, the excess flow will over flow from manholes’ lids into streets, and contaminates its way

Effect of “I & I” on sewer system

B- Treatment plant's capacity

- Capacity of the plant is designed based on the **expected** waste water from **customers**, and its expected **life span** (for example **30** years)
- If the plant, is designed to operate with **50%** of its capacity by the **10th** year, and remaining **50%** is left for **future** growth in (**next 20** years)
- A few settlements of **large** gravity pipes in the **first 10** years can add an additional flow of **50% of I & I** and will demand **100%** of the plants capacity leaving **no** room for future development and growth.
- **Urgent** capital will be needed for plant **expansion** or **new** plant

Effect of “I & I” on sewer system

C- Sewer system's **operating** cost

- The operating cost of waste water from customers to injection wells varies by city, ranging from \$1.16/1000g in Salt lake city to \$ 17.38/1000g in Atlanta.
- Residential rate for city of Ft. Lauderdale is \$5.07/1000g with an annual **growth** rate of 5%
- about 50% of this cost is due to I & i
- 50% of annual **running cost** of sewer system is for “I & I”
- by elimination of “I & I”, system's **running energy** will be reduced to 50%

IS “I & I” DETECTABLE ?

YES & NO

YES : Inflow is detectable and measurable. It is responsible for less than 0.5% of total “I & I” and its shows as flow surge in the entire sewer system

NO : Continuous Infiltration of underground water is invisible & undetectable, it is responsible for about 99.6 % of total “I & I”.

Total I&I can be accurately estimated!

1. Identify catch basins on city area map
2. In each catch basin, select minimum of five random houses with irrigation water meters
3. Find annual irrigation water for those houses, $Q_{(irr.)}$
4. Find landscape area of those houses, $A_{(land. s.)}$ in ft^2
5. From 3 & 4 above find annual water irrigation index

$$W_{(irr. Index)} = \frac{Q_{irr.}}{A_{land. S.}} \quad (GALLON/ 1000 Ft^2) / year$$



Total I&I can be accurately estimated!

6. From aerial map, calculate the **total** landscape area **irrigated** by city's water, $A_{(T. \text{ land s.})}$ in Ft^2
7. Total irrigation water by city's water will be, $Q_{(T. \text{ irr. })} = A_{(T. \text{ land. s.})} \times W_{(\text{ irr. index})}$ in gallons/year
8. $Q_{(\text{flush})}$, is the annual water flush **out** by hydrant flushing, for water system cleaning
9. $Q_{(\text{ real sewer})} = Q_{(\text{ water system})} - Q_{(\text{ flush})} - Q_{(T. \text{ irr.})}$ R. sewer ,gal./year
10. $Q_{(T.I \ \& \ i)} = Q_{(\text{ periodic rain)}} + Q_{(\text{ continuous under ground)}}$
11. $Q_{(T.I \ \& \ i)} = Q_{(\text{ pant inflow})} - Q_{(\text{ real sewer})}$

“ **INFLOW** ” PREVENTION,

- Adding rubber gaskets to manhole lids (~\$100/lid)
- community **policing**, for any water dumping into manholes or connection of storm drain to sewer system



INFILTRATION,

- “Infiltration” is the **intrusion** of **rain** water or **under ground** water **into** sewer systems underground
- Infiltration **can** be **classified** as:
 - A– **dry** soil periodic **rain** water infiltration
 - B– **wet** soil periodic **rain** water infiltration
 - C– **continuous** under **ground** water infiltration

B- Coastal Cities:

- In coastal cities under ground water **level** is at the depth of **5' to 15ft**, and the majority of gravity sewer **pipes** are **submerged** in under ground **water**.
- **Dry soil** infiltration is **noticeable** during rain, **specially** when the ground is **flooded** and dry soil become saturated.
- The **annual dry soil** infiltration in coastal cities compare to **total annual** water intrusion is **insignificant** and is near **0.0 %**

B-Wet soil periodic rain infiltration,

- Wet periodic rain infiltration refer to intrusion of rain water ,when u. g. water rises and more gravity pipes become submerged
- In this case, the net imposing water pressure is “h”. “h” is distance of the joint to under ground water table.
- This pressure head at the joint will convert to water velocity “ v ” and causes water to rush in to the pipe, that will show as flow surge in sewer plant

JOINT'S VELOCITY,

The water **velocity** at a joint's opening that is a distance **h** below the underground water **level** is given by:

$$V = (2g.h)^{1/2}$$

where;

V : is the water **velocity** at joint opening (**ft/sec**)

g : is gravity **acceleration** and is (**32.2 ft/sec²**)

h : is water **head** (distance of joint to **u. g.** water (**ft**)



RUSH IN FLOW,

If the open joint has area of “A” (inch²), then the water infiltration by pressure of “h” in (ft), in Gpm will be;

$$Q_{(gpm)} = 3.125 V_{(ft/sec)} \times A_{(inch^2)}$$

$$Q_{(gpm)} = 25.08 h^{1/2} \times A_{(inch^2)}$$

Example:

$$A = 1 \text{ inch}^2, h = 4 \text{ ft}$$

$$Q_{(gpm)} = 25.08 \times 4^{1/2} \times 1 = 50.16 \text{ G.p.m}$$

Wet periodic infiltration has a delay of start about
2 to 3 hours in respect to rain start



42

Infiltration Gusher, at 04
o'clock, within 8 inches of joi
YES

0077.7 F

01/22/15 09:00

SIGNIFICANCE OF WET PERIODIC RAIN IN COASTAL CITIES:

Periodic rain intrusion **increases** the sewer **flow**, it is detectable and can be **measured**

➤ In coastal cities, the total I&I from **rain** is the sum of:

A– inflow

B– dry soil water infiltration

C– wet soil water infiltration

➤ Annual rain water “**I&I**”, in compare to **continuous**
u. ground **water** infiltration is insignificant (**under 0.5 %**)

“CONTINUOUS” INFILTRATION,


Happens **only** in **coastal** cities, where under ground water table is in depth of **4’** to **15** feet.

- **65–100 %** of gravity sewer pipes are **submerged**, and **35–0 %** of pipes are in **dry** soil
- Such sewer system is subjected to “**Inflow**”, “ **dry** periodic infiltration”, and “ **wet** periodic infiltration” caused by rain, as well as “**continuous**” infiltration by **under** ground water.
- **Contribution** of the “**continuous u. g.**” water to total annual water intrusion is **significant**, is near **100%**
following case study proves this claim

CASE STUDY,

A gravity sewer pipe made of 4 ft sections of 10" clay pipe, is in service for less than two years. it is shown in Fig.1 , with the following data.

- Pipe length: 6,000 ft.
- Installation slope: 0.0025ft/ft(with manning no of 0.013)
- Annual average under ground water depth: -6 ft.
- Depth of starting manhole : -4 ft.
- Depth of end pipe connected to lift-station :-19 ft.



NEWLY INSTALLED GRAVITY PIPE ARE STRAIGHT AND LEAK FREE

CLAY SEWER PIPE, 10" DIA., 6,000.Ft., WITH 5% LEAKY JOINTS

CASE STUDY, CONTINUE,

- Gravity pipe is relatively **new** and only **5 %** of joints in **dry & wet** soil have opening with width from (**1 / 8"** to **0.0"**) x **16"** length , that is equal to **1.0 inch²**
- Ft. Lauderdale has annual average of **62.18 inch** of **rain** for last **30** years.
- Lets assume **31** rainy days per year with **2"** of **rain** with duration of **6 hours** every time
- **18"** diameter manhole's lid has **1 / 16"** crack over **80 %** of lid's perimeter, that is equal to **2.8 inch²**



CASE STUDY, CONTINUE, CALCULATION

A- INFLOW:

Rain inflow in man whole 's lid is calculated with
Head pressure “h” of 2” of rain for 6 hours

$$V_{(Ft/sec)} = (2g.h)^{1/2} = 8.025 \times h^{1/2} \dots\dots\dots(1)$$

$$Q_{(GPM)} = 450 V_{(Ft/sec)} \times A (Ft^2) \dots\dots\dots(2)$$


Where:

V : Is water velocity at the lid's crack in (Ft/sec)

Q : Is inflow water through the lid in (GPM)

g : is gravity acceleration, and is 32.2 in (Ft/sec²)





$$V = \sqrt{2gh} = 8.025 \frac{\text{Ft}}{\text{sec}}$$

$$Q = V * A = 3.34 \text{ GPM}$$

$$V = \sqrt{2gh} = 31.08 \frac{\text{Ft}}{\text{sec}}$$

$$Q = V * A = 12.95 \text{ GPM}$$

PRESSURE HEAD = "h"

PIPE OPENING = "A"

RELATIONSHIP OF PRESSURE HEAD "h" & VELOCITY "V"

RELATIONSHIP OF FLOW RATE "Q" & VELOCITY "V" & "A"

CASE STUDY, CALCULATION CONT.

G : Gallon, each Ft^3 is equal to 7.49 gallons ($1/7.5 \text{ Ft}^3$)

A : Area of crack in (Ft^2)

Substitution of values in equations 1 & 2

$$V = 8.025 \times 0.408 = 3.276 \text{ Ft/sec} \quad \text{in (Ft/sec)}$$

$$Q_{\text{(GPM)}} = 450 \times 3.276 \text{ Ft/sec} \times 2.8 \text{ in}^2 / 144 \quad \text{in (GPM)}$$

$$Q_{\text{(GPM)}} = 28.67 \text{ GPM}$$

$$Q_{\text{(G/YEAR)}} = 28.67 \text{ GPM} \times 6 \text{ (Hrs)} \times 60 \text{ (min.)} \times 31 \text{ (Day/year)}$$

$$Q_{\text{(G/YEAR)}} = 319,957 \text{ G/YEAR} = 0.32 \text{ MG/YEAR} \quad \text{(MG/year)}$$



CASE STUDY, CALCULATION CONT.

B- DRY SOIL PERIODIC RAIN INTRUSION,

- per fig.1, 800 ft of pipe is in dry soil
- 200 joints are located in dry soil,
- 5 % of joints (10 joints), each one has 1 in² opening
- Water pressure head is 2" , (0.167ft)
- Water velocity at joints' crack "V" is $V = 3.28 \text{ ft/sec}$
- Opening area = 10 joints x 1 / 144 = 0.0695 ft²
- $Q_{(GPM)} = A \times V = 0.695 \times 3.28 \times 7.5 \times 60 = 102.6 \text{ GPM}$
- $Q_{(G/YEAR)} = 102.6 \text{ GPM} \times 6 \text{ (Hrs)} \times 60 \text{ (min.)} \times 31 \text{ (Day/year)}$
- $Q_{(MG/YEAR)} = 1,145,016 \text{ G/YEAR} = 1.145 \text{ MG/YEAR}$

CASE STUDY, CALCULATION CONT.

C – WET SOIL PERIODIC RAIN INTRUSION,

- 5,200 ft. Of pipe is submerged in U.G. water
- 1,300 joints are under water
- 5 % of joints equal to 65 joints have opening of 1 in²
- Total area of joint opening = 0.451 ft²
- Water velocity at joint = 3.28 ft/sec
- $Q_{(GPM)} = A \times V = 0.451 \times 3.28 \times 7.5 \times 60 = 665.7 \text{ GPM}$
- $Q_{(G/YEAR)} = 665.7 \text{ GPM} \times 6 \text{ (Hrs)} \times 60 \text{ (min.)} \times 31 \text{ (Day/year)}$
- $Q_{(MG/YEAR)} = 7,429,212 \text{ G/YEAR} = 7.429 \text{ MG/YEAR}$

CASE STUDY, CALCULATION CONT.

D – CONSTANT UNDER GROUND INFILTRATION,

- 5,200 ft. of pipe is submerged in u.g. water
- 1,300 joints are submerged under water
- 5 % of joints equal to 65 joints have opening of 1 in2
- Total area of joint opening = $65/144 = 0.451 \text{ ft}^2$
- The joint's pressure head varies from 0.0 to 13 ft.
- Average “ V ” at joints with “h” = 6.5 ft = 20.46 ft/sec
- $Q_{(GPM)} = A \times V = 0.451 \times 20.46 \times 7.5 \times 60 = 4,152.4 \text{ GPM}$
- $Q_{(G/YEAR)} = 4,152.4 \text{ GPM} \times 24_{(Hrs)} \times 60_{(min.)} \times 365_{(Day/year)}$
- $Q_{(MG/YEAR)} = 2,182,490,928 \text{ G/YEAR} = 2,182.5 \text{ MG/YEAR}$

INTRUSION CALCULATION SUMMARY

- Inflow of rain water, periodic, only in rainy days

$$Q_{(MG/YEAR)} = 0.32 (MG/YEAR)$$

- Dry soil infiltration, periodic, only in rainy days

$$Q_{(MG/YEAR)} = 1.145 (MG/YEAR)$$

- Wet soil infiltration, periodic, only in rainy days

$$Q_{(MG/YEAR)} = 7.429 (MG/YEAR)$$

- U.G. Water intrusion, constant, invisible, always

$$Q_{(MG/YEAR)} = 2,182.5 (MG/YEAR)$$

- The ratio of periodic intr. To constant is **0.407 %**

CRAVITY PIPE CONDITION,

- Gravity pipe at its **start** point is connected to **4 ft.** depth starter man whole, and at the other **end** it is connected to a intermediate manhole or a lift **station**
- At the **time** of installation, the pipe **center** line is straight with slope of **0.0025 ft./ft.**
- The **dry soil** portion of pipe, does **not** experience buoyant force, and it is **anchored** in hard dry soil
- Therefor **dry soil** pipe remain as **original** condition.



CAUSES THAT OPEN THE JOINTS:

A- CAUSES IN DRY SOIL,


- The main cause for joint opening in dry soil part of the pipe, is tree roots,(especially rubber tree), that move toward the leaky joints for water and food, and gets in the pipe and open the joints wider.
- Lateral movement of soil, unstable underneath layer could cause lateral or vertical joint opening.

8

-45 A18-42



ots Ball Lateral, from 12 to 1
clock, 100 %, within 8 inches
int: YES



filtration Gusher, from 04 to 10
clock, within 8 inches of joint:
S

180.0 F

01/26/15


08:10a

B – JOINT'S OPENING CAUSES IN WET SOIL,


a–ALONG THE PIPE'S LENGTH,

Portion of gravity pipe in the **wet soil** and **submerged** location is straight with leak free joints, at the time of **installation**

- During the service, the joints are subjected to **alternative** vertical **force**. This force is the cause of developing **open joints** by moving the pipe up & down, and **loosen** all the joints
- This **force** is always **upward**, and it **bends** the pipe **upward**, its Center line **curves** up ward and become **longer**
- This elongation will be compensated by **slid out** the joints



IN EXISTING LIFT-STATIONS, GRAVITY SEWER PIPE **GOES** UNDER
OSCILLATING BUOYANT **FORCE**



B – JOINT'S OPENING CAUSES IN WET SOIL,(cont.)

b-AT THE PIPE'S ENDS,

- Gravity sewer pipe at **start** point is connected to **start** manhole , this **end** connection is **rigid** and all bending moment by up lift force will be absorbed by the **part** of **pipe** that is **anchored** in hard **dry** soil
- Pipe end at **lift-station** connection, as result of up lift **alternative** force imposing to entire submerge portion, **vertical force** and **clockwise** moment, rotate and pulls **out the pipe end**, and create a **big** opening for u.g. water to rush in to lift-station.

B – JOINT'S OPENING CAUSES IN WET SOIL,(cont.)

c– ALTERNATE FORCE,

A 12" dia. gravity pipe made of 20 ft. sections , carry near zero flow in midnight, and almost full at 6 pm. it is submerged in loose soupy wet soil

- The buoyant up lift force acting on one ft. of pipe is

$$B = 3.1416 w .D^2 . L/4 (lb./Ft)$$

$$B = 3.1416 \times 62.4 \times 1 \times 1 / 4 = 49 lb./ Ft. (in midnight)$$

$$B = 3.1416 \times 0.0 \times 1 \times 1 / 4 = 0.0 lb./Ft. (at 6.00 pm)$$

- The joints under alternate force become loose. this force is continuously upward, cause pipe bends upward

B – JOINT'S OPENING CAUSES IN WET SOIL,(cont.)

d– BUOYANT FORCE OF END CONNECTION TO L.S.

Above 12" dia. gravity pipe , is connected to L.S., at the depth of 19 ft. with u.g. water at the depth of 6ft. the water head pressure at the connection is 13 ft.

- Consider only 3 pipe sections, with 2 intermediate joints, each with the rigidity of 67 % in transferring of bending moment of buoyant force to connection.
- $B/20''\text{pipe} = 49 \text{ lb..../Ft.} \times 20' = 980 \text{ lb.}$ (in midnight)
 $M_{(\text{at connection})} = 980 (10' + 0.67 \times 30' + 0.67 \times 0.67 \times 50') \text{ lb.} \times \text{Ft.}$
 $F_{(\text{uplift of 3pipes})} = 3 \times 980 \text{ lb.} = 2,940 \text{ lb.}$ (acts on connection)

B – JOINT'S OPENING CAUSES IN WET SOIL,(cont.)

d– BUOYANT FORCE OF END CONNECTION TO L.S. (cont.)

$$F_{(TOTAL)} = F_{(UPLIFT)} + F_{(MOMENT)}$$

$$M_{(connection)} = 51,178 \text{ lb.} \times \text{Ft.}$$

$$\text{MOMENT ARM} = \text{PIPE Dia.}/2 = 1 \text{ Ft.}/2 = 0.5 \text{ Ft.}$$

$$F_{(MOMENT)} = M_{(connection)} / 0.5 \text{ Ft.} = 102,356 \text{ lb.}$$

$$F_{(TOTAL)} = 2940 \text{ lb.} + 102,356 \text{ lb.} = 105,296 \text{ lb.}$$

$$A_{(RESISTING \text{ AREA OF CONCRETE})} = \text{PIPE Dia.}_{(OUT \text{ SIDE})} \times 1 \text{ inch}^2$$

$$S_{(STRESS)} = 105,296 \text{ lb.}/ 13 \text{ in}^2 = 8,100 \text{ PSI}$$

$$S = 8,100 \text{ PSI} > 4,000 \text{ PSI} \text{ AND CONCRETE WILL CRASH}$$



INFILTRATION IN LIFT-STATIONS:

- Existing lift-stations are made from 5 to 8 cylinders with 5' to 6 ft. height, and male & female joints. they are stacked top of each other with sealing compound.
- Wrongfully believed , that the weight of top section is sufficient to make the joints water tight.
- In coastal cities, lift-stations joints are one of the main sources of water infiltration in to lift-stations
- Following calculation determines the magnitude of uplift forces that separate the lift stations' joints.



CALCULATION UPLIFT FORCE IN L.S.

A WET WELL, 12' Dia .MADE OF 6 CYLINDERS WITH 6' HIGHT, AND 12" WALL FROM REINFORCED CONCRETE.

a- WEIGHT OF ONE CYLINDER & TOP SLAB

$$W_{(\text{cylinder})} = 3.14 \times w_c \times D_{(\text{mean})} \cdot t \times H \text{ (lb.)}$$


$$W_{(\text{top slab})} = 3.14 \times w_c \times D_{(\text{outer})}^2 \times h/4 \text{ (lb.)}$$

WHERE,

$W_{(\text{cylinder})}$: IS THE WEIGHT OF ONE CYLINDER (lb.)

$$D_{(\text{mean})} = D_{(m)} = (D_{(\text{inner})} + D_{(\text{outer})})/2 = 13"$$

w : IS SPESIFIC WEIGHT OF CONCRETE = 150 (lb./Ft ³)



LIFT-STATION, 12'x 30'

264.3 FT.

ANTIOCH AVE.

D40-8

CLAY PIPE CIRCULAR 8

FACTORY MADE DEFECTIVE, AT 03 O'CLOCK,

WITHIN 8 INCHES OF JOINT: YES,

IG

11-02-04 02:19

CALCULATION UPLIFT FORCE IN L.S. (cont.)

H : HIGHT OF CYLINDER (Ft.) = **6 Ft.**

h : HIGHT OF TOP SLAB (Ft.) = **1 Ft.**

t : IS WALL TICKNESS = **12 in**

D_i , **D_m** , **D_o** : INNER Dia., MEAN Dia., OUTER Dia. = **12 “, 13”, and 14”**

b– **BUOYNT** FORCES ACTTING ON LIFT-STATION'S **PIPE** CONNECTION

$$\mathbf{B}_{\text{(buoyant forces)}} = \mathbf{BF}_{\text{(up lift)}} + \mathbf{BF}_{\text{(moment)}} \quad (\text{lb.})$$

WHERE,

B : IS THE TOTAL **BUOYANT FORCE** ACTTING ON **CONNECTION** (lb.)

BF_(up lift) : IS THE REACTION FORCE OF CONNECTION = $3 \times 980 = \mathbf{2,740}$ lb.

BF_(moment) : $M/\text{Arm} = 51,178 \text{ lb.... Ft.} / 0.5\text{Ft.} = \mathbf{102,356}$ lb.

$$\mathbf{B} = \mathbf{BF}_{\text{(uplift)}} + \mathbf{BF}_{\text{(moment)}} = 2,740 + 102,356 = \mathbf{105,096} \text{ lb.}$$



CALCULATION UPLIFT FORCE IN L.S. (cont.)

c- THE **FORCES** ACTING ON JOINT “CC”, WILL BE AS FOLLOWING

$$1- W_{(\text{concrete})} = 3 \times W_{(\text{cylinder})} + W_{(\text{top slab})}$$

$$W_{(\text{concrete})} = 3 \times 36,757 \text{ lb.} + 23,091 \text{ lb.} = 133,362 \text{ lb.}$$

$$2- B_{(\text{buoyant})} = 105,096 \text{ lb.}$$

$$d- M_{(\text{CC})} = B_{(\text{buoyant})} \times 13.5' - W_{(\text{concrete})} \times 7' \text{ lb.} \times \text{Ft.}$$

$$M_{(\text{CC})} = 105,096 \times 13.5' - 133,362 \times 7' = \text{lb.} \times \text{Ft.}$$

$$M_{(\text{CC}) (\text{net})} = 1,418,796 - 933,534 = 485,262 \text{ lb.} \times \text{Ft.}$$

e- **UPLIFT** FORCE ON JOINT “CC” JUST UNDER THE **PIPE** WILL BE,

$$F_{(\text{uplift-net})} = M / \text{Arm} = 485,262 / 14' = -34,662 \text{ lb.}$$

➤ JOINT “CC” WILL BE **SEPARATED** AT MINIMUM FLOW (**MIDNIGHT**)

INFILTRATION IN MANHOLES

In the recent years gravity sewers are made with PVC pipe sections of 20 ft. with rubber gasket push in joints. They run from manhole to manhole or to lift-stations.

At the both end of their connections they will create a upward bending moment, when become submerged.

This moment creates an up lift force at the manhole joint below the pipe and just under the pipe.

- Those cracks are temporary, invisible, main source of infiltration, no stain, (be washed continuously by inflow).

RECOMMENDATIONS FOR NEW INSTALLATION

A-GRAVITY SEWER LINE,

- a- Instead **clay** sections of **20' PVC** with push in rubber gasket should **be used**
- b- In **submerged** portion of gravity line, each **20'** pipe to **be** anchored at the **center**, to prevent bending **up ward**. Anchor should be a **helical** disk of **8"** or **10"**
- c- The **existing** method of pipe **connection** to lift station and manhole should be **revised** as follows



RECOMMENDATIONS FOR NEW INSTALLATION (cont.)

A– GRAVITY SEWER LINE,(cont.)

- ❖ Connecting pipe to lift–station must be anchored at 7' from connecting point, with solid anchor tie to lift–station or manhole.
- ❖ A conical reinforced connection should connect the pipe to lift–station or manhole as follows,
 - The diameter of cone at connection is (3x pipe's dia.) and other side of cone with (2x pipe's dia.).
 - The cone's length ,should be at least 3'ft.
 - Min. of (12) re–bars #5, 3 ft. length with 4" embedment 6 at top, 6 at bottom, in 120° at top & bottom
 - Min .4,000 psi concrete should be used

RECOMMENDATIONS FOR NEW INSTALLATION (cont.)

B-LIFT-STATIONS & MANHOLES

a- Water intrusion to wet well completely eliminated.
with pre fab. green wet well by global green lift.

all sections of green wet well have flange and will
stacked on top of each other . Their flanges
connect together, using gasket and bolts & nuts.

b- In traditional concrete wet well ,the joints under
the pipe connection, should be reinforced vertically
with stainless-steel 316 plate and Topcon Fasteners
this reinforcement will absorb the uplift force of
pipe connection moment.



EXISTING SEWER SYSTEM,

“ I & I “ in both rain and u.g. continuous infiltration, “Q”
eq.(1) or (2), is a function of joint opening area
“A” and water velocity “V” at the joint, or water
pressure head “ h “.

$$Q = A \times V \dots\dots\dots (1)$$

$$Q = 8.025 A \times h^{1/2} \dots\dots\dots (2)$$

By elimination of “A” or “ h “ or both, “I &I” will be eliminated

EXISTING SEWER SYSTEM, (cont.)

A-ELEMINATION OF JOINT OPENINGS “A”.

At present time the industries' focus is, to eliminate joints opening by the following methods.

- a- In **clay** gravity **pipe**, continuous **inner lining** with **PVC** liquid and harden it with **steam**.
- b- Find open **joint** with **camera**. seal it locally from **inside**, by blocking both side of the joint and **inject** sealant with pressure.
- c- polyurethane injection from **out** side of the opening, most commonly **used** is in manholes and **lift**-stations

➤ ALL OF THE ABOVE ARE VERY COSTLY



EXISTING SEWER SYSTEM, (cont.)

B-REDUCTION OR ELEMINATION OF “h”


- **Continuous** “I & I” is under ground water intrusion that is responsible for **99.6 %** of total “I & I”
- The **force** behind this infiltration is U.G. water **head** “h”, that varies along the gravity sewer line.
- Per **eq.(2)**, when “h” reduces and approaches to zero, “Q” also will reduces and approaches to zero.
- Reduction of “h” is a **new concept** . It is not in the interest of industry, because it is **not profitable** to them. **Therefore their experts will criticize it.**

EXISTING SEWER SYSTEM, (cont.)

SIMPLE SOLUTION FOR ELEMINATION OF “ h “ WITH NO CAPITAL COST,

- “h” varies from 0.0 at starting manhole to 20 ft. in lift station connection.
- “h” at one joint varies when under ground water oscillates seasonally.
- Green lift-station design with its special control system is able to reduce “h” at any desired amount from 20 ft. to 1 ft.
- the smart green lift-stations by Global Green Lifts are capable of following the seasonal variation of u.g. water level and maintain the “h” value as low as 8 inches at all the time.






GREEN LIFT-STATION PROTECTS GRAVITY SEWER PIPE FROM
BUOYANT FORCE

REDUCTION OF (I & i) WITH OUT CAPITAL & RUNNING COST BY GLOBAL GREEN LIFT-STATIONS

ITEMS	GROUND DEPTH TO		EFFECTIVE ORIGINAL WATER HEAD Ft.	PRESSURE REDUC. by GLOB. G.L. STATION Ft.	EFFECTIVE PRESSURE USING G.G.L.STA. Ft.	AVE.PRESSURE ALONG G.PIPE USING G.G.L.STATION Ft.	AVE.VILOCITY ALONG PIPE $v=\sqrt{2gh}$ $v= 8.025\sqrt{h}$ Ft./SEC.	REDUCTION of Q (I & i) $\frac{Q(I \& i)G.G.}{Q(original)}$ %	PLANT RESEVE CAPACITY by G.G.L.STA. %	PLANT OPERAT. FLOW by g.g.l.s %
	PIPE CONNec. Ft.	U. G. WATER Ft.								
1	19	6	13	0	14	7	20.46	100%	0.00%	100%
2	19	6	13	2	11	5.5	18.82	92%	4%	96%
3	19	6	13	4	9	4.5	17.02	83.20%	8.40%	91.60%
4	19	6	13	6	7	3.5	15.01	73.40%	13.30%	86.70%
5	19	6	13	8	5	2.5	12.67	61.92%	19.04%	80.96%
6	19	6	13	10	3	1.5	9.83	48.04%	28%	72%
REDUCTION OF (I & i)WITH OUT CAPITAL& RUNNING COST WITH SMART G. W. LEVEL SENSING GREEN LIFT-STATIONS										
7	19	6	13	11	2	1	8.02	39.22%	30.39%	69.61%
8	19	6	13	12	1	0.5	5.67	27.73%	36.14%	63.86%
9	19	6	13	12.34	0.66	0.33	4.61	22.53%	38.74%	61.26%
1- AT THE POINT OF CONNECTION TO L.STATION h= 13 Ft. AND VELOCITY V= 28.93 Ft./SEC.										
2 - IN SIDE PRESSURE IS 12.34Ft. AND V= 28.19Ft./SEC.										
3-THERE IS INFLOW FROM INSIDE OF PIPE TO OUT SIDE WITH V= 0.75 Ft./sec.										

APPLICATION OF **GREEN LIFT**-STATIONS TO CONTROL “ I & i ” AND INCREASE PLANT **CAPACITY**

REDUCTION OF “ I&i ” DOWN FROM **100%** TO **23%** , AND PLANT’S **RESERVE CAPA.** UP FROM **0%** TO **40%**



PLANT **RESERVE** CAPACITY INCREASES FROM **0%** to **40%** BY **GREEN** L.STATION
GREEN L.STATION WILL SAVE RUNNING **COST** AND ENERGY COST BY **40%**

NEAR TOTAL ELIMINATION OF “I&I” WITH LIMITED FUND.

Most of the cities have very **limited fund**, or fund is **spread** over period of **several** years. It is essential in fighting with “ I&I ”, take a **route** with the minimum **cost** and maximum **benefit**. The following are **steps** toward to this **effort**.

1–All existing pump–stations should be ranked per following equation.

$$R = 100 * \frac{h_h}{H} * \frac{(5Lc + Lp)}{L_t} * \frac{a}{30}$$

Where:

R : is the **ranking** number

h_h: is the highest U.G. Water table among the city’s sewer basins.

H : is the U.G. Water table of **individual** sewer basin

a : is the service **age** of gravity sewer, and **30** year is the life span of the pipe

NEAR TOTAL ELIMINATION OF “I&I” WITH LIMITED FUND,(cont.)

L_c : is the total length of **clay** gravity sewer pipe

L_p : is the total length of **PVC** and Ductile **Iron** sewer pipe

L_t : is the total length of lift-station gravity sewer pipe

2– Select the **twenty** top lift-stations from above **ranking**.

3– Apply clamp ultra sound **flow meter** for a period that include at least **four** rainy days, and collect **data** for rainy and sunny days.

4– **Average** flow data of rainy and sunny days for **20** lift-stations, should be calculated. The **ratio** of **rainy** day flow to **sunny** day flow should be obtained.

5– Applying above **ratios**, new **ranking** for **20** lift-stations in order of **descending** should be arranged.

6– With consideration of available **fund** a number of lift-stations, in order of ranking, should be **selected** for “I&I” elimination.

DESIGN PROCESS TO ELIMINATE “I&I” WITH LIMITED FUND.

The following processes in order of priority should be followed

- 1– All selected lift–stations, should be converted to Green lift–stations technology. This will reduce the total “I&I” from 100% to 30% without any capital spending for “I&I” projects.
- 2– For eliminating of remaining 30%, establish a pilot project for top five lift–stations and implement the following steps, while monitoring the Lift–stations’ discharge flow.
 - a– Check the gravity pipe connections to lift–stations and manholes. The lift–station’s male& female connection joint under inflow pipe should be reinforced with stain less steel strap & S.L.S.Tapcon screws, when connection is not leaking.

DESIGN PROCESS TO ELIMINATE “I&I” WITH LIMITED FUND,(cont.)

- b– Lining the old, submerged gravity clay pipe start from lift–station to under ground water level.
- c– With camera check the connection of lateral to gravity main and repair the broken connections locally.
- d– With camera inspect the remaining clay pipe, and repair it , if it is needed.
- e– Seal the manholes’ lids with rubber gasket.
- f– with continuous monitoring the discharge flow, the effectiveness of each step can be measured.
- g– most likely beyond these stages, a minor improvement could achieve with a major expense.

This pilot project, provide us a tested guideline for rest of Stations

CITY OF FORT LAUDERDALE:

The **Running cost** of City **Sewer System** is the **topic** of this **study**.

- 1–Population: **172,389** people and annual growth rate of **1.25%**.
- 2–Area: The Total area is **38.6** square miles,(99.9 sq. Km.), with;
 - a– Dry land area: **34.7** square miles,(90 sq. km).
 - b– Water area: **3.8** square miles,(9.9 sq. km).
- 3– Elevation: **9** Ft.(2.75 m) from Sea.
- 4– Rain Fall: Average of **62.18** inches annually in last **30** years.
- 5– The highest **single** day rain fall is **12.25** inches in **Oct.1942**.
- 6– City Sewer System Annual Running cost of “**Pump in**” and “**pump out**”.

A– Lift–Stations:

- a– The Total city L.S. with two and three pumps is **216** L.S.
- b– The Total City Horse Power installed in Lift–Stations: **9,470** H p

B– GTL Deep Well injection: with total of four pumps.

- a– Two pumps, **880** Kw,(**1180** H p), each. **2,360** H p
- b– Two pumps, **1234** Kw,(**1655** H p),each. **3,310** H p



ANNUAL SEWER SYSTEM **RUNNING** MATERIAL, & ENERGY **COST** **EXISTING (Sept 2014 to Sept 2015)**

1-chlorine	\$ 70,584	
2-hydrogen Peroxide	\$345,612	
3-polymehrs	\$284,227	
4-liquied Oxygen	\$ 87,748	
5-water/Sew/Storm	\$354,735	
6- Running Energy used		
a-pumping In , Lift-stations		
10,382,792kwhx 10cents	\$1,038,279	
b-pumping Out , Power Deep Well		
20,313,670kwhx 7.26 Cents	\$1,474,772	
c- inside GTL, power		
6,879,053kwhx7.26 Cents	\$ 499,419	
<hr/>		
➤ Total Running Cost	\$4,155,376	(100%)

(I & i) RELATION with RUNNING MATERIAL, & ENERGY COST

City of Ft. Lauderdale is a coastal City with serious (I & i) problem.

The City's amount of (I & i) is not known. The City personals believe the (I & i), will be between 55% to 60% of inflow entering to GTL.

In this study a conservative number of 55% has been used.

From 100 Ga of inflow, 45 Ga is real sewer and 55 Ga is clean U. G. water In form of (I & i).

IF, we reduce (I & i) from existing of (100%) to (25%), then:

$$\text{Inflow}_{\text{(new)}} = 45 \text{ Ga}_{\text{(real sewer)}} + 55 \text{ Ga}_{\text{(I \& i)}} \times 25\% = 58.75 \text{ Ga}$$

The resulting saving on running cost will be;

$$\text{SAVING}_{\text{(I \& i) reduction}} = 100\% - 58.75\% = 41.25\%$$

$$\text{SAVING}_{\text{(I \& I from 100\% to 25\%)}} = 41.25\% \times 4,155,576 = \$ 1,714,092.-$$



HOW (I & i) CAN BE REDUCED from 100% to 25%?

One of the following **methods** could be used.

- 1 – If the gravity sewer pipe is **clay**, too old, too long, and too deep it is **feasible** to be replaced by a new Lift-Station with a shallow force main.
- 2 – **LINING:**
To day common practice, is **inside lining** with PVC.
To achieve **75%** reduction, about **75%** of gravity sewer pipe should be **lined**.
 - City of Key west, with **25,000** population spent \$ **65.million** in its **(I & i)** project. Its **capital index** is \$ **2,600.–** per person.
 - There is **close** similarity between key west and Ft. Lauderdale and Key west **index** can be used for **(I & I)** budget estimation for FT. Lauderdale, and estimated budget will be;
 - **Capital cost**= 172,389 x\$ 2,600= **\$ 448.2 millions**

HOW (I & i) CAN BE REDUCED from 100% to 25% ? Conti.

- If the reduction is 75%, then the City's Saving will be \$1,714,092.
Years of Capital Return = $\$448.2 / 1.714 = 261.5 \text{ years}$
- Lining has **limited** life,
Per Manufacturer the **lining** material last **50** years in **testing** lab, but working conditions not lab condition. In sewer gravity pipe lining is expose to harsh chemical, corrosive and erosive condition, and mechanical stresses. Lining **loses** its elasticity, become **brittle** and fail. It might last **20** to **25** years.
- Economically, it is not feasible:
In **25** years, the total compounded capital return is ;
 $29.135 \times \$1,714,092 = \49.940 million
The **Capital Loss** would be $\$448.2 - \$49.940 = \$398.26 \text{ million}$
The **Annual Capital Loss** would be $\$398.26 / 25 \text{ years} = 15.93 \text{ million/year.}$
- lining **can not** be qualified for **Federal Grant**.



HOW (I & i) CAN BE REDUCED from 100% to 25% ? Conti.

3-Applying Green Lift Technology :

➤ **No Capital Cost:**

By conversion of existing Lift-stations to **Green lift- stations**, the (I & i) reduction of **75%** will be achieved **with out** any capital cost for(I & i).

➤ **Annual saving:**

Due to (I & i) reduction of 75%, there is a Saving of;
 $4,155,376. \times 41.25\% = \$ 1,714,092.$

with **Smart Green-Lift-Station**, even further saving is possible.

➤ **No life limitation:**

The life of (I & i) saving is unlimited.

➤ **Green-Lift -Stations Save Energy, and are qualified for Federal Grant.**

➤ **GTL Capacity Expansion:**

The GTL treatment capacity, will be expanded from **100%** to **141.25%**. No plant expansion is required for another 30 years.

➤ **Environmentally is friendly, less CO2 be released to atmosphere.**



TOTAL ANNUAL ENERGY SAVING by GREEN-LIFT-TECHNOLOGY

Applying Green-Lift-Technology to “**pumping process**”, will results
In the Following Energy Savings:

a- (I & i) REDUCTION: Energy saving by 75% (I & i) reduction is;

➤ **Saving** _(I & i) = \$3,012,470. x **41.25%** = \$1,242,644.

b- LIFT-STATIONS:

Conversion of existing L.S. to Green lift-stations will result in energy
saving of **40%** on reduced inflow of **58.75%** of original flow.

➤ **Saving** _(L.S.) = 1,038,279 kwh x 58.75% x 40% x 10 c/kwh = \$ 243,996.

c- GTL DEEP WELL:

By applying the Green-Lift Technology and constant speed pumps, will
be a **saving** of **70%** on reduced inflow of **58.75%** of original flow.

➤ **Saving** _(GTL) = 20,313,670 kwh x 58.75% x 70% x 7.26 c/kwh = \$606,500.

Total **Energy Saving** by “**Green lift Tech.**”. \$ 2,093,140. (69.48%)



ANNUAL SEWER SYSTEM, MAINTENANCE SAVING by GREEN-LIFT TECHNOLOGY

By conversion of existing Lift-Stations to Green-Lift-Stations, and by applying the Green-lift Technology in “ **pumping process** “, the pump’s **life span** will increase by **400%**.

Further more, costly repair and every **6 to 8 years**, replacement of **VFDs** Totally will be eliminated.

The exact amount of annual maintenance for lift-stations is not known. The average existing maintenance cost, for lift-stations and GTL is;

a- Lift- Stations: \$2,200,828.

b- Deep well injection: \$1,384,692.

a- Lift-Stations:

Saving by Green-Lift is averaged to **65%**.

Annual Saving in L.S. = **65%** x 2,200,828. **\$1,430,538.**

b- Deep Well injection:

Saving by Green-lift Technology estimated **to 75%**.

Annual Saving in GTL deep well = **75%** x \$1,384,692. **\$1,038,519.**

Total Annual Maintenance **Saving** **\$2,469,057.**



CONVERSION COST of EXISTING L.STATIONS to GREEN-L. STATIONS

To **convert** the existing Lift-Stations to **Green Lift-Stations** the following modification should be done.

1– Integration of Green–lift control with existing control.	\$ 15,000.
2– Remove and replace the top slab with Green lift cover.	\$ 10,000.
3– Remove of pumps and replace them with three smaller, pumps with total Hp. Installed 60 to 70% of existing, and piping arrangement.	\$ 60,000.
4– Data gathering, and engineering.	\$ 15,000.
5– Over head and profit.	\$ 20,000.

Average Total Conversion Cost /each	\$120.000.

6– City's Total **Conversion Cost**= 216 x \$ 120,000.= **\$ 25,920,000.**

7– Annual **Saving** by **Green lift** technology is; \$5,033,645.

8– The **Annual Rate of Return** is $\$5.033/25.92 = \mathbf{19.42\%}$

SUSTAINABILITY & ENVIRONMENTAL IMPACT

Sewer System Total Energy Used in **2015** is: **37,575,515 Kwh**

Annual energy Saving in Sewer System, by
" **Green Lift Technology**".

1– **Saving** by (I & i) reduction, (**41.25%**) , is:

$$37,575,515 \text{ Kwh} \times 41.25\% = 15,499,900 \text{ Kwh}$$

2– **Saving** of **40%** in L. Stations with
constant speed pumps is:

$$10,382,792 \text{ Kwh} \times 58.75\% \times 40\% = 2,439,956 \text{ Kwh}$$

3– **Saving** of **70%** in Deep Well with
elimination of VFDs.

$$20,313,670 \text{ Kwh} \times 58.75\% \times 70\% = 8,353,997 \text{ Kwh}$$

Total **Annual Energy Saving**: **26,293,853 Kwh**

To generate, **1Kwh** electricity, **2.18** lb. (near **1Kg**) **CO₂**
along with other Toxic gasses, will be **released** into **atmosphere**.

➤ **CO₂** (**not released**) = $2.18 \text{ lb} \times 26,293,853 \text{ Kwh} = 28,660 \text{ tons/year}$



SEWER SYSTEM ANNUAL RUNING COST OF EXISTING, and SAVING BY APPLYING GREEN- LIFT TECHNOLOGY

	PERIODS	1-YEAR	5 YEAR PERIOD		10 YEAR PERIOD		25 YEAR PERIOD	
I T E M S	DESCRIPTION	YEAR 2015	2015 to 2020		2015 to 2025		2015 to 2040	
		VALUES	Accumulated	Accumulated	Accumulated	Accumulated	Accumulated	Accumulated
		YEAR	5 years with	5 years with	10 years with	10 years with	25 years with	25 years with
		2015	0% Inflation	2% Inflation	0% Inflation	2% Inflation	0% Inflation	2% Inflation
		\$ C1	\$ 5.1266 C1	\$ 5.3384 C1	\$ 10.582 C1	\$ 11.610 C1	\$ 29.1354 C1	\$ 37.805 C1
	Runing Cost:							
1	Runing Energy &Material	4,155,376.-	21,302,951.-					
2	Runing Lift-station Maint.	2,200,828.-	11,282,765.-					
3	Runing GTL D.W.Maint.	1,384,692.-	7,098,762.-					
	Total Annual Runung Cost	7,740,896.-	39,684,477.-	41,323,999.-	81,914,161.-	89,871,803.-	225,531,005.-	292,605,869.-
A	<u>Saving by (I&I)Reduction</u>							
	From 100% to 25%	1,714,092.-	8,787,464.-	9,150,509.-	18,138,522.-	19,900,608.-	49,940,070.-	64,801,248.-
	<u>Saving By G.L. Technology</u>							
B1	40% energy saving in lift-							
	Stations by Green-Lift	243,996.-	1,250,870.-					
B2	70% energy saving In GTL	606,500.-	3,109,283.-					
B	Sub Total Eenergy Saving	850,496.-	4,360,153.-	4,540,288.-	8,999 949.-	9,874,259.-	24,779,201.-	32,148,749.-
	<u>Maintenance Saving by</u>							
	Green Lift-Technology							
C1	65% in Lift-station Maint.	1,430,538.-	7,333,796.-					
C2	75% in Deep well injecti.	1,038,519.-	5,324,072.-					
C	Sub Total Maint.Saving	2,469,057.-	12,657,868.-	13,180,814.-	26,127,561.-	28,665,752.-	71,935,976.-	93,330,355.-
T S	TOTAL Annual Saving by							
	Green Lift Technology	5,033,645.-	25,805,484.-	26,871,610.-	53,266,031.-	58,440,618.-	146,665,247.-	190,271,781.-

Conclusion:

- 1 – Elimination of (I & I) in coastal cities is essential and **MUST** be done. Several methods have been used, the most common practice is **inside lining** of gravity pipes, but it is not the best, and other methods may be feasible.
- 2 – For very old large clay pipe, (specially when it is submerged and long), it is cheaper to be replaced with new small lift station and shallow force main.
- 3 – **Pipe Lining:**
 - a – It is costly,
 - b – Its effective **life** is **limited** due to harsh working condition of mechanical and chemical stresses. Most of the time it does not return its initial capital cost.
 - c – It **can not** be qualified for **Federal Grant**.
 - d – It has **negative return**, actually Annual capital **loss** of **15.93** million.
- 4 – (I & I) elimination by Green-Lift Station:
 - a – Very **low** initial **capital** cost.
 - b – **No** life limitation.
 - c – It will be in **top** list of **Federal Grant** projects.
 - d – Its Annual Energy saving is over **69.48%** of existing Energy used.
 - e – Environmentally is **friendly**, less energy associated with **less CO2**.
 - f – It **preserve** the sewer collecting system from **further** deterioration.



Q questions

&

A answers